



Safety & Buildings Division
201 West Washington Avenue
P.O. Box 2658
Madison, WI 53701-2658

Evaluation #

200125-H (Replaces 950063-H)
Revision #2

Wisconsin Building Product Evaluation

Hot Water Heaters:

Manufacturer: Heat Transfer Products, Inc.
120 Braley Road, P.O. Box 429
East Freetown, Massachusetts 02717

Approved Product(s): OEM: Heat Transfer Products, Inc., Trade

Name: Super Stor Voyager: SSV76(-45S, -50S), SSV90(-45S, -50S), SSV100(-45R, -50R, SSV130(-30D, -45R, -50R, -45S, -50S, -80R, -80S, -119R, -119S), SSV160 (-45S, -50S, -80R, -119R), SSV199(-45S, -50S, -80R, -119R). SSVH (90, 130, 199)(-45, -50, 80)(S, R). Note: Voyager series SSV & SSVH model numbers may be prefixed with a 'C' for Canadian models, & followed by an 'A' or 'B' to designate a warranty code, & may be followed by a 'LP' to designate fuel type. Heat-Tek Industries-OEM: Heat Transfer Products, Inc., Trade Name: Sani-Sav: SA(-130,-160, -199)(-45, -80, -119). OEM: Heat Transfer Products, Inc., Trade Name: Super Stor Voyager Sanitizer: SA(90-, 130-, 160-, 199-)(45, 50). Natco/National Combustion Co., Inc. -OEM: Heat Transfer Products, Inc., Trade Name: Natco Super-E Voyager Super Stor: SE199(-45, -80, -119). Rheem Mfg. Co., Water Heater Div. -OEM: Heat Transfer Products, Inc., Trade Name: Advantage Plus: HE(45, 50, 80, 119)(-100, -130, -160, -199).

Note: Sani-Sav series SA-, Sanitizer series SA-, and Super-E series SE- model numbers may be followed by a 'LP' to designate fuel type. The Advantage Plus series HE- model numbers may be followed by an 'N' or 'LP' to designate fuel type.

SCOPE OF EVALUATION: "This evaluation was based on receipt of a signed statement from the testing agency that the product passed the Wisconsin code required test(s) see test section. No other Department evaluation was conducted."

Applicant/Manufacturer: _____

Date: _____

ANSI Z21.47 (ANSI Z21.64): Access to the combustion chamber requires the use of tools.

_____ P.E.

Date: _____

TESTS: All models were tested and certified in accordance with ANSI Z21.10.3 by Underwriter's Laboratories, Inc. as a Direct Vent Sealed Combustion Chamber Appliances, and as defined in **s. Comm 51.01 (29a)** and specified in **s. Comm 64.21(3)**.

LIMITATIONS OF APPROVAL: The water heaters shall be installed in accordance with their listing and the manufacturer's recommendations.

The water heaters covered by this evaluation meet the definition of a Direct Vent Sealed Combustion Chamber Appliance as specified in **s. Comm 51.01 (29a)** and may be installed without a rated enclosure, as allowed in **s. Comm 64.21(3)**.

Architectural and mechanical plans and specifications shall be submitted in accordance with the requirements outlined in **ss. Comm 50.07 and Comm 50.12** as stated in **Comm 63.01**.

This approval will be valid through December 31, 2006, unless manufacturing modifications are made to the product or a re-examination is deemed necessary by the department.

The Wisconsin Building Products Evaluation number must be provided when plans that include this product are submitted for review.

DISCLAIMER: The department is in no way endorsing or advertising this product. This approval addresses only the specified applications for the product and does not waive any code requirement not specified in this document.

Revision Date:

Approval Date: 9/12/01 By: _____

Lee E. Finley, Jr.
Product/Material & Review
Integrated Services Bureau

200125-H.doc